


S Broadwater
627.8 Missouri (Toston)
N7btd Dam emergency
1993 action plan

add back 28989477 SP

BROADWATER- MISSOURI (TOSTON) DAM EMERGENCY PLAN



PLEASE RETURN

DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

WATER RESOURCES DIVISION

STATE WATER PROJECTS BUREAU

AUGUST 1993

MONTANA STATE LIBRARY

S 627.8 N7btd 1993 c.1

Broadwater-Missouri (Toston) Dam emergen



3 0864 00086874 8

BROADWATER-MISSOURI (TOSTON) DAM

EMERGENCY ACTION PLAN

Broadwater-Missouri (Toston) Dam
FERC. Project No. 2853

State Water Projects Bureau
Water Resources Division
Montana Department of Natural Resources
and Conservation
1520 East Sixth Avenue
P. O. Box 202301
Helena, Montana 59620-2301

Revised August 1993



Digitized by the Internet Archive
in 2015

<https://archive.org/details/broadwatermissou1993mont>

Verification:

STATE OF [Montana]

County of [Lewis & Clark] ss:

The undersigned, being duly sworn, states that (he, she) has read the following document and knows the contents of it, and that all of the statements contained in that document are true and correct, to the best of (his, her) knowledge and belief.

Glen McDonald
Name of person signing

State Water Projects, Bureau Chief
Title

STATE OF MONTANA)

County of Lewis & Clark

On this 27th day of July, 1993, before me, a Notary Public for the State of Montana, personally appeared Glen McDonald, known to me to be the person whose name is subscribed to the within instrument, and acknowledged to me that (he, ~~she~~) executed the same.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed my Notarial Seal the day and year first above written.

Jeffrey Kim
Notary Public for the State of

Montana

Residing at _____ NOTARY PUBLIC for the State of Montana
Residing at Helena, Montana

My commission expires _____
~~My Commission Expires August 1, 1995~~

CONTENTS


	Page No.
I. Notification Flowcharts	1
A. Failure is Imminent or Has Occurred	1
B. Potentially Hazardous Situation is Developing.	3
II. General Responsibilities Under the Emergency	
Action Plan	5
A. Purpose.5
B. Notification Plan.6
C. Operations11
D. Notifying Local Officials.12
E. Updating Local Officials14
F. EAP Coordinator.14
III. Notification Procedures	15
A. Failure is Imminent or Has Occurred - Attended	
Condition	15
B. Failure is Imminent or Has Occurred - Unattended	
Condition	17
C. Potentially Hazardous Situation is Developing -	
Attended Condition.	19
D. Potentially Hazardous Situation is Developing -	
Unattended Condition.	20
E. Posting of the Notification Flowchart and	
Distribution of EAP	22
IV. Preventive Actions.	23
A. General Provisions for Surveillance	23
B. Surveillance at Remotely Controlled or	
Unattended Dams	25
C. Response During Periods of Darkness	28
D. Response During Periods of Adverse Weather.	28

CONTENTS CONTINUED


E.	Availability and Use of Alternative Systems of Communication.	29
F.	Emergency Supplies and Resources.	30
G.	Other Concerns and Actions.	31
V.	APPENDICES	32
A.	Description of Broadwater-Missouri Dam	A-1
B.	Broadwater-Missouri Power Project Dam Break Analysis	B-1
C.	Flood Inundation Maps.	C-1
D.	Plans for Posting the EAP, Training, Testing, and Annual Review.	D-1
E.	Documentation.	E-1
F.	Location Maps.	F-1
G.	Telephone Directory.	G-1

I. NOTIFICATION FLOWCHARTS

A. FAILURE IS IMMINENT OR HAS OCCURRED NOTIFICATION FLOWCHART BROADWATER-MISSOURI DAM



NOTIFICATION FLOWCHART BROADWATER-MISSOURI DAM



II. General Responsibilities Under the Emergency Action Plan

A. Purpose

This Emergency Action Plan (EAP) has been prepared in accordance with the requirements of the Federal Energy Regulatory Commission (FERC) Order Number 122 issued January 21, 1981 and revised in accordance with the provisions of Section 12.22 (a)(1), on April 5, 1985 (issued on February 22, 1988 with addendum issued September 9, 1988). It is submitted by the Montana Department of Natural Resources and Conservation (DNRC), Water Resources Division, State Water Projects Bureau (SWPB), as Licensee for the Broadwater Power Project on the Missouri River, which is FERC Licensed Project No. 2853.

The purpose of this EAP is to provide maximum early warning to all persons involved in the unlikely event of failure (catastrophic or otherwise) of any project structure at the Broadwater Power Project. In addition to providing maximum early warning, the objective is to minimize danger to all people or property downstream.

Through modeling different failure modes and the resultant breach hydrographs, inundation zones have been developed and are shown on the inundation maps included in Appendix C. The inundation boundaries help identify residential, commercial, and recreational areas that would be at risk. Notification flowcharts were developed to facilitate evacuation and warnings at potentially affected areas by various public agencies and authorities.

The information contained in this plan is not intended to reflect in any way upon the actual integrity of the Broadwater Dam.

B. Notification Plan

The notification flowcharts in Section I identify the agencies and people to be contacted during an actual or developing dam failure. The notification procedure to implement at Broadwater Dam is dependent upon the following variables: the rate of dam failure (failure scenario), and whether the dam is attended or unattended.

The two dam failure scenarios for the Broadwater Dam are: A) failure is imminent or has occurred, and B) potentially hazardous situation is developing. When a "**failure is imminent or has occurred**" condition exists at Broadwater Dam, then Flowchart A is implemented. However, when the Broadwater Dam has a "**potentially hazardous situation is developing**" scenario, then Flowchart B is implemented. Identifying the type of failure scenario existing at Broadwater Dam allows one to initiate the appropriate notification flowchart.

The notification procedures are also influenced by whether the Broadwater Dam is attended or unattended during a dam failure. When the dam is unattended, generally, the **Plant Operator** or the **Plant Superintendent** is the first one alerted of a potential problem by the automatic telephone dialing system at the plant. When the dam is attended, the **Plant Operator** is the first one alerted of a potential problem. Therefore, the notification procedure is normally initiated by the **Plant Operator**.

The **Plant Operator's** notification responsibility for the Broadwater Dam is outlined below.

1. Notification Responsibilities

a. Attended

If a "**failure is imminent or has occurred**", and the control room is attended, then the **Plant Operator's**

first responsibility will be to notify the **Broadwater County Sheriff**. The **Plant Operator** shall then notify the **Plant Superintendent** by telephone. The **Plant Superintendent's** primary responsibility, upon receiving notification from the **Plant Operator**, is to notify the **Project Supervisor**.

If you cannot reach the person that is next on the call down list, then you must assume their duties and responsibilities.

Under this failure scenario the **Plant Superintendent** will advise the **Project Supervisor** that a breach floodwave is approaching Toston and Townsend and to take appropriate action.

If a "potentially hazardous situation is developing" and the control room is attended, then the **Plant Operator's** first responsibility is to notify the **Plant Superintendent**. The **Plant Superintendent's** primary responsibility, upon receiving notification from the **Plant Operator**, is to notify the **Project Supervisor**. The **Project Supervisor** will first notify the **SWPB Chief** and second the **Broadwater County Sheriff** if the developing conditions make the notification of the sheriff necessary.

b. Unattended

When the control room is unattended, then the **Plant Operator** may be alerted of a problem by an alarm. The **Plant Operator** will be either the **Plant Operator** or the **Plant Superintendent** depending upon who is on call. The two types of alarms that signal a warning to the **Plant Operator** are the general plant shutdown

alarm and the low reservoir level alarm. The responsibilities of the **Plant Operator** for the two alarm conditions are outlined below.

When the **Plant Operator** is on vacation or leave, then the **Plant Superintendent** assumes the **Plant Operator's** duties, as well as his/her own duties. When the **Plant Superintendent** is on vacation or leave, then the **Project Supervisor** assumes the **Plant Superintendent's** duties, as well as his/her own duties. When the **Project Supervisor** is on vacation or leave, then the **Plant Superintendent** assumes the **Project Supervisor's** duties, as well as his/her own duties.

When a general plant shutdown alarm occurs then the **Plant Operator's** normal responsibility is to access one of the remote SCADA terminals to verify the condition, then travel to the project and investigate the cause of the alarm.

The remote SCADA terminals are located in the powerhouse at the dam, in the DNRC office building in Helena and in the **Plant Operator's** home in Townsend.

If, during the investigation the **Plant Operator** determines that a "failure is imminent or has occurred" condition exists, his/her first responsibility is to call the **Broadwater County Sheriff** and other personnel as identified on Flowchart A.

When a low reservoir level alarm sounds, then the **Plant Operator** is required to call the **Plant Superintendent**, then access one of the remote SCADA

terminals to verify the condition, then travel to the dam and verify the condition, by visually checking the condition at the plant and verifying headwater and tailwater elevations. Once it's been determined that it's not a false alarm, and a **"failure is imminent or has occurred"** condition exists, the **Plant Operator's** primary responsibility is to notify the **Broadwater County Sheriff** and other personnel identified in Flowchart A. In the meantime, the **Plant Superintendent** will travel to the Department office building and monitor headwater and tailwater conditions. If the **Plant Superintendent** concludes a **"failure is imminent or has occurred"** condition exists, he/she must call the **Broadwater County Sheriff**.

The **Plant Superintendent** shall also notify the **Project Supervisor** that a **"failure is imminent or has occurred"** condition exists at the Broadwater Dam and they should take appropriate action.

2. Communication Examples (attended or unattended)

In times of an emergency, clear and concise exchange of information is essential. The **Plant Operator** when making the call to the **Broadwater County Sheriff** for a **"failure is imminent or has occurred"** scenario, shall include the following points:

- Caller's name and position
- Caller's location
- Brief description of situation
- The time of situation
- Intended follow-up actions

- Appropriate Notification Flowchart to initiate

IMPORTANT - ASK THE PERSON RECEIVING YOUR MESSAGE TO REPEAT IT BACK TO YOU SO THAT YOU WILL KNOW THAT THEY RECEIVED THE CORRECT MESSAGE AND UNDERSTAND HOW THEY ARE TO PROCEED.

A typical communication from a **Plant Operator** to the **Broadwater County Sheriff** under "failure is imminent or has occurred" condition may be as follows: "This is John Doe, operator at Broadwater Dam. Spillway Bays #6 & 7 failed between 11:45 a.m. and noon. The breach is approximately 100 feet wide and 40 feet deep. The Missouri River flow at the time of failure was 50,000 cfs, therefore initiate Notification Flowchart A. I am evacuating the site."

The **Plant Operator** when making the notification call to the **Plant Superintendent** for a "potentially hazardous situation is developing" condition shall include the following points:

- Caller's name and position
- Caller's location
- Brief description of the potential problem
- Brief assessment of the potential problem
- Intended follow-up actions
- Appropriate Notification Flowchart to initiate

A typical communication from the **Plant Operator** to the **Plant Superintendent** for a "potentially hazardous situation in developing" condition may be as follows: "This is John Doe, operator at Broadwater Dam. The

middle portion of the dam has a severe leak. Approximate flow from the leak is 50 cfs. I am requesting you to initiate notification procedures for a **"potentially hazardous situation is developing"** condition. Flows in the Missouri River are about 6,000 cfs, therefore initiate Notification Flowchart B. I will stay on site and monitor the situation."

The **Plant Superintendent** will report a **"potentially hazardous situation is developing"** condition to the **Project Supervisor**. The **Project Supervisor** will contact the **SWPB Chief** and the **Broadwater County Sheriff** if the condition warrants. If the **SWPB Chief** is contacted, he will decide if other SWPB personnel will be contacted for assistance. The **SWPB** will discuss possible solutions to the problem. These steps will be performed in order to provide assistance to the **Plant Operator**. However, the **Plant Operator** monitoring the problem is at liberty to initiate notification for a **"failure is imminent or has occurred"** condition whenever he/she feels it is warranted.

C. Operations

Once the **Plant Operator** has completed the appropriate notification procedures, then he/she will implement the emergency operation procedures. The **Plant Operator** during the emergency condition will have to determine whether he/she can safely perform all steps in the operation procedures. Outlined below are the emergency operation procedures for both a **"failure is imminent or has occurred"** condition and a **"potentially hazardous situation is developing"** condition.

1. **Failure is imminent or has occurred.**

- Step 1 Evacuate all station personnel
- Step 2 Alert all people immediately downstream to
 evacuate to higher ground (use bullhorn).
- Step 3 Alert all people located above the dam to exit
 the reservoir (use bullhorn).
- Step 4 Shut down the unit using emergency procedures.
- Step 5 Open all the spillway air bags.

Note: Steps 4 and 5 should be initiated only if they can be
 performed safely.

2. **Potentially hazardous situation is developing.** (The
following steps shall be initiated only at the direction of
the **Plant Superintendent** or the **Project Supervisor**).

- Step 1. Evacuate all nonessential personnel including
 boaters and fishermen.
- Step 2. Shut down unit using normal procedure.
- Step 3. Open the spillway air bags.

D. Notifying Local Officials

The **Plant Superintendent** shall notify the people identified below
when implementing the notification procedures for a "**failure is
imminent or has occurred**" condition. The **Plant Superintendent**
shall communicate to responsible personnel the following points:

- Caller's name and title
- A warning that a dam failure has or is about to occur
- Evacuate all personnel to higher ground immediately

The **Plant Superintendent** shall notify the following agencies in the order listed:

1. Broadwater County Sheriff (unattended only)
2. Project Supervisor

Phone numbers and personnel for the above agencies are located in Flowchart A, Section III Notification Procedures and Appendix G, Telephone Directory.

The **Plant Operator** shall be responsible for warning those recreating in the reservoir or just below the dam of a "**failure is imminent or has occurred**" condition. The **Plant Operator** when evacuating the site shall position himself along the road and use a bullhorn to warn recreationists. The warning must clearly express dam failure is imminent and evacuation from the Missouri River must begin immediately.

The **Broadwater County Sheriff** will coordinate evacuation, rescue and mitigation of all parties affected by a Broadwater Dam failure. The **Broadwater County Sheriff** is responsible for coordinating these activities within his jurisdiction. The responsibilities of the **Broadwater County Sheriff** in times of a dam failure are outlined in the "Emergency Operation Plan for Broadwater County and City of Townsend" in the section titled "Dam Failure/Flood, Contingency Plan."

After notifying the appropriate personnel, the **Plant Operator** is responsible for monitoring the situation. The monitoring process will include an evaluation to determine the condition's state as progressive or static. The **Plant Operator** will also evaluate whether any immediate action can be taken to mitigate the condition.

The **Plant Operator** will continuously maintain communication with the **Plant Superintendent** during the monitoring process. This monitoring and communication link will continue until the **Plant Superintendent** or the **Project Supervisor** direct changes to the procedure, or until conditions change such that the monitoring is no longer required.

E. Updating Local Officials

The **Project Supervisor** is required to notify the local agencies when initiating notification procedures for "**failure is imminent or has occurred**" condition. Local officials and the media will be updated by the **Project Supervisor** of changes in the condition of the dam.

The **Project Supervisor** has the responsibility of notifying local agencies of a "**potentially hazardous situation is developing**" condition. The **Project Supervisor** in turn shall notify and update local agencies of conditions at the project site using Flowchart B and Section III Notification Procedures.

F. EAP Coordinator

The EAP Coordinator is Walt Anderson, Project Supervisor. Some activities Mr. Anderson will coordinate are revisions to the EAP, training seminars for plant operators, and annual testing of the EAP. Mr. Anderson's office address is: 1520 East 6th Ave., Helena, Montana 59620-2301 and he can be reached at (406) 444-6646.

III. Notification Procedures

A. Failure is imminent or has occurred - Attended Condition.

Plant Operator's notification responsibilities for a "failure is imminent or has occurred" condition.

1. Notify the **Broadwater County Sheriff** and advise him/her of the situation by telephone:

Sheriff Dispatch Center 266-3441 (24 hrs)

2. Notify the **Plant Superintendent** and advise him/her of the situation by telephone:

Plant Superintendent Pager 449-1550 (24 hrs)

Mike Sims Office 444-6646

Home 442-0552

Note: If the Plant Operator cannot notify the Plant Superintendent, then the Plant Operator is responsible for the Plant Superintendent's notification calls in addition to notifying people located near the project with a bullhorn.

Plant Superintendent's notification responsibilities for a "failure is imminent or has occurred" condition.

Notify the **Project Supervisor** and advise him/her of the situation by telephone:

Project Supervisor Office 444-6646

Walt Anderson Home 443-3016

The Project Supervisor's notification responsibilities for a
"failure is imminent or has occurred" condition.

1. State Water Projects Bureau Chief Office 444-6646
Glen McDonald Home 443-5758

or

Project Rehabilitation Supervisor	Office	444-6646
Greg Ames	Home	449-6261

2. Federal Energy Regulatory Commission

Harry T. Hall	Office	1-503-326-5844
	Home	1-503-636-6861
Arthur Martin	Office	1-503-326-5840
	Home	1-503-635-1472

3. Water Users Association

Bob Davis, President	Home	266-3786
Gordon Brug, Ditch Rider	Home	266-5798

The Broadwater County Sheriff's notification responsibilities for a "failure is imminent or has occurred" condition.

Broadwater County DES

Mike Wenzel	Office	266-3441 (24 hrs.)
	E.O.C.	266-5241
	Home	266-3220
	Church	266-4219

State Water Project Bureau Chief's notification responsibilities for a "failure is imminent or has occurred" condition, day or night.

1. State Water Project Bureau Personnel (see telephone Directory in Appendix G)
and

Dam Safety Section	Office	444-6613
Mike Oelrich	Home	449-5668
Gary Fischer	Home	442-8818
Water Resources Division	Office	444-6601

2. National Weather Service 453-2081 (24 hrs)
3. Canyon Ferry Power Plant Operator 475-3310 (24 hrs)

B. Failure is imminent or has occurred - Unattended Condition.

When the dam is unattended, the **Operating Personnel** are warned of an emergency condition, either by a low reservoir level alarm or by a general plant shutdown alarm. The **Plant Operator's** response to the two alarm conditions is outlined below.

When the Plant Operator is on vacation or leave, then the Plant Superintendent assumes the Plant Operator's duties, as well as his/her own duties. When the Plant Superintendent is on vacation or leave, then the Project Supervisor assumes the Plant Superintendent's duties, as well as his/her own duties. When the Project Supervisor is on vacation or leave, then the Plant Superintendent assumes the Project Supervisor's duties, as well as his/her own duties.

When the Plant Operator receives a low reservoir level alarm, he/she shall:

1. Notify the Plant Superintendent

Mike Sims	Pager	449-1550 (24 hrs)
	Office	444-6646
	Home	442-0552

2. Access one of the remote SCADA terminals to verify the condition.

The remote SCADA terminals are located in the powerhouse at the dam, in the DNRC office building in Helena and in the Plant Operator's home in Townsend.

and

3. Travel to the dam to verify its condition. If the **Plant Operator** upon arriving at the dam determines that a "**failure is imminent or has occurred**" condition exists, he/she shall call the **Broadwater County Sheriff** and initiate Flowchart A.

The Plant Superintendent shall verify the alarm condition by performing the following steps:

- Step 1) Check SCADA display screen for a significant rise in the tailwater over a brief time period.
- Step 2) Check SCADA display screen for a significant decrease in the headwater over a brief time period.

Once the verification steps have confirmed a significant rise in the tailwater accompanied with a drop in headwater, then the **Plant Superintendent** shall be responsible for initiating notification procedures for a "**failure is imminent or has occurred**" condition and notify:

1. The **Broadwater County Sheriff** and advise him/her of the situation by telephone:

Sheriff Dispatch Center	266-3441 (24 hrs)
-------------------------	-------------------

2. The **Project Supervisor** and advise him/her of the situation by telephone:

Project Supervisor	Office	444-6646
Walt Anderson	Home	443-3016

When one of the **Operating Personnel** receives a general plant shutdown alarm, then he/she shall access one of the remote SCADA terminals to verify the condition, then travel to the dam and investigate the cause. The time for the **Plant Operator** to arrive on site is twenty (20) to forty (40) minutes.

Once the **Plant Operator** is on site, the procedures for the attended condition shall be followed.

C. **Potentially hazardous situation is developing - Attended Condition.**

Plant Operator's notification responsibilities for a "**potentially hazardous situation is developing**" condition:

Notify **Plant Superintendent** and advise him/her of the situation:

Mike Sims, Plant Superintendent

Phone:	Office	444-6646
	Home	442-0552
	Pager	449-1550 (24 hrs)

Plant Superintendent's notification responsibilities for a "**potentially hazardous situation is developing**" condition.

Notify **Project Supervisor** and advise him/her of the situation:

Walt Anderson, Broadwater Plant Supervisor

Phone:	Office	444-6646
	Home	443-3016

Note: The **Project Supervisor** will report the situation to **Chief, SWPB**. Depending upon the nature of the potentially hazardous situation, mitigation measures will be discussed with the **SWPB** before a specific course of action is chosen. If deemed necessary, the **Project Supervisor** will notify the following:

1. State Water Projects Bureau

Glen McDonald	Office	444-6646
	Home	443-5758

or

Project Rehabilitation Supervisor

Greg Ames	Office	444-6646
	Home	449-6261

2. Broadwater County Sheriff 266-3441 (24 hrs)

3. Federal Energy Regulatory Commission

Harry T. Hall	Office	1-503-326-5844
	Home	1-503-636-6861
Arthur Martin	Office	1-503-326-5840
	Home	1-503-635-1472

4. Water Users

Bob Davis, President	266-3786
Gordon Brug, Ditch Rider	266-5798

D. Potentially hazardous situation is developing - Unattended Condition.

When the dam is unattended, the **Operating Personnel** are warned of an emergency condition either by a low reservoir alarm or by a general plant shutdown alarm. The **Plant Operator's** response to the two alarm conditions is outlined below. When the Plant Operator is on vacation or leave, then the Plant Superintendent assumes the Plant Operator's duties, as well as his/her own duties. When the Plant Superintendent is on vacation or leave, then the Project Supervisor assumes the Plant Superintendent's duties, as well as his/her own duties. When the Project Supervisor is on vacation or leave, then the Plant Superintendent assumes the Project Supervisor's duties, as well as his/her own duties.

When the Plant Operator receives a low reservoir level alarm, he/she shall:

1. Notify Plant Superintendent and advise him/her of the situation:

Mike Sims, Plant Superintendent

Phone:	Office	444-6646
	Home	442-0552
	Pager	449-1550 (24 hrs)

2. Access one of the remote SCADA terminals to verify the condition.

The remote SCADA terminals are located in the powerhouse at the dam, in the DNRC office building in Helena and in the Plant Operator's home in Townsend.

and

3. Travel to the dam and investigate the alarm. If the Plant Operator upon arriving at the dam determines that a "potentially hazardous condition situation is developing" condition exists, he/she shall again notify the Plant Superintendent and initiate Flowchart B.

Plant Superintendent's notification responsibilities for a "potentially hazardous situation is developing" condition.

Upon receiving the first call from the Plant Operator that a low reservoir level alarm exists, the Plant Superintendent shall investigate the alarm condition by performing the following steps:

Step 1) Check remote SCADA display screen for a significant rise in the tailwater over a brief time period.

Step 2) Check remote SCADA display screen for a significant decrease in the headwater over a brief time period.

Once the investigation steps have confirmed that the headwater and tailwater levels are stable, then the **Plant Superintendent** shall wait for a second call from the **Plant Operator** who is enroute to the plant or already there and investigating the alarm. When the **Plant Superintendent** receives the second call from the **Plant Operator** and is notified that a "**potentially hazardous situation is developing**" condition exists, he/she shall notify the **Project Supervisor** and advise him/her of the situation by telephone:

Project Supervisor	Office	444-6646
Walt Anderson	Home	443-3016

When one of the **Operating Personnel** receives a general plant shutdown alarm, then he/she shall access one of the remote SCADA terminals to verify the condition, then travel to the dam and investigate the cause. Once the **Plant Operator** is on site, the procedures for the attended condition shall be followed.

E. **Posting of the notification flowchart and distribution of EAP.**

Copies of the notification flowcharts for both "**failure is imminent or has occurred**" and "**potentially hazardous situation is developing**" scenarios shall be posted at the following locations:

1. Broadwater Power Project Control Room
2. State Water Projects Bureau Office - Helena (all engineers have a copy)
3. Plant Operator's Home
4. Broadwater County DES Coordinator - Townsend
5. Broadwater County Sheriff's Office - Townsend
6. Federal Energy Regulatory Commission - Portland Office

7. Broadwater-Missouri Water Users Association Directors
8. Department of Natural Resources and Conservation
Library
9. State Library
10. State Disaster and Emergency Services - Helena
11. Ditch Rider
12. Montana Power Company in Butte

A copy of the complete up-to-date EAP will be distributed to each agency and individual identified in the notification plan in Section III. Each complete copy of the EAP distributed will include one spare copy of each notification flowchart for posting. The additional copies of the notification flowcharts shall be included at the end of the Appendix E, Documentation. Each plan holder will receive revisions to the plan as necessary. Additional copies of the most up-to-date notification flowcharts can be obtained by contacting the EAP Coordinator, Walt Anderson (406) 444-6646.

IV. Preventive Actions

A. General Provisions for Surveillance

The Broadwater Dam is monitored by a **Plant Operator** eight hours a day and by a Supervisory Control and Data Acquisition (SCADA) system twenty-four hours a day.

Surveillance of the dam will be performed principally by the **Plant Operator**. The **Plant Operator** will be the primary observer; other persons may report problems with the dam when they are in the area. The duties will include observation of dam safety related checklist items including seepage, cracks, settlement, debris, erosion, etc. The ditch rider is normally at the dam once a day

during the irrigation season, but not year-round, and may observe and report problems.

The SWPB makes yearly physical inspections of the dam. The dam is equipped with post tensioning anchor system monitors, piezometers adjacent to the powerhouse, and a headwater/tailwater level monitoring system. An inspection report is written and compared to previous inspection reports.

When the project is unattended, the Supervisory Control and Data Acquisition (SCADA) system will report power plant alarm conditions to the **Plant Operator** at a remote location. A dam failure would be detected by headwater/tailwater level monitor alarms. A telephone dialer would notify the **Plant Operating Personnel** of an alarm condition. The **Plant Operator** will access one of the remote SCADA terminals to verify the condition, then travel to the dam and visually check its condition. Personnel living in Helena can check the condition of the dam at the SCADA remote terminal in the Department's office. The **Broadwater County Sheriff's Office** will be contacted either from the dam or from the Department offices in Helena, and informed of the condition of the dam.

The **Plant Operator** is trained annually on inspection procedures. The **Plant Operator** learns to identify any unusual sound, smell, vibration or heat source around the plant. The **Plant Operator** is also trained to monitor the general condition of the project structures and station equipment. The various items that are inspected daily by the **Plant Operator** are listed below:

Daily Inspection:

1. Substation
 - a. Make a general switchyard inspection.

- b. Make a general transformer and breaker inspection.
2. Dam waterways and spillway gates
- a. Inspect all spillway gates.
 - b. Inspect piers, right and left abutments for leaks or cracks.
 - c. Inspect trash rack at turbine intake.
 - d. Check headwater staff and compare with plant meters.
 - e. Check for icing conditions of all waterways upstream and downstream.
 - f. Check all boater safety booms and associated safety equipment.
3. Powerhouse
- a. Make a general inspection of all components.
 - b. Check SCADA for alarms and investigate.
 - c. Check and record critical temperatures, water levels, and outputs from SCADA.
 - d. Check all fluid levels, flow status, and pressure.
 - e. Check all pumps, motors, pressure vessels and compressors.
 - f. Check for leaks and general condition of all: lubricating oil system, hydraulic system, cooling water system, and seal water system.
 - g. Check battery room charger and batteries.
 - h. Check general operating condition of the automatic upstream head level control.

B. Surveillance at Remotely Controlled or Unattended Dams

The Broadwater powerhouse and appurtenances are continuously monitored by a Supervisory Control and Data Acquisition (SCADA) system. The SCADA system consists of the following components: transducers, remote terminal unit (RTU), communications input/output controller, computer and monitor. The SCADA system

transducers are sensors that signal an alarm condition. The two alarms that may be sounded are:

1. General Plant Shutdown Alarm

The SCADA monitors the status of a variety of systems located in the Broadwater powerhouse. Some examples of alarm points being monitored for generation systems are: over current or ground, generator over speed, lubricating oil reservoir levels, bearing temperatures and stator temperatures. When normal operating conditions are exceeded for these and other systems, then a general plant shutdown alarm sounds.

When a general plant shutdown alarm sounds, the specific alarm point's status is displayed on the SCADA alarm summary located in the Broadwater Control Room, the **Plant Operator's** home in Townsend and the Department Office building in Helena. If the control room is attended, then the **Plant Operator** will be required to identify, inspect and mitigate the problem. If the **Plant Operator** encounters difficulty in clearing the alarm, he/she will notify the **Plant Superintendent**. In addition, the general plant shutdown alarm warning is printed to a data logger with the date and time of occurrence.

2. Low Reservoir Level Alarm

Water level transducers are installed in the headwater and tailwater at Broadwater to monitor water surface elevations. The level transducers are linked into the SCADA system through the RTU located in the Broadwater powerhouse and the Helena office to provide continuous monitoring of actual levels.

When a signal is transmitted from the reservoir level transducer, which is below a given set point, a low reservoir level alarm is annunciated by an automated phone calling system. **Plant Operating Personnel** are notified of the low level and must travel to the dam to investigate.

When a low reservoir level alarm sounds, the **Plant Operator** shall be required to verify whether a dam failure has occurred. Confirmation of a dam failure is made by visually inspecting the dam and appurtenant structures at Broadwater. This will allow the **Plant Operator** to determine whether a false alarm condition exists or whether a dam failure has occurred.

A quality control program is maintained to insure the integrity of the SCADA system at Broadwater Dam. This program tests and inspects all transducers, meters, relays, annunciator, and panel alarms annually at the Broadwater plant. After testing the system, all nonfunctional or worn components are replaced. Upon installation of new components, a test is run to assure all systems are functional.

C. Response During Periods of Darkness

No additional actions can be taken to respond to an emergency situation or failure at the dam during darkness, other than those taken during daylight hours. The response time will be longer because of the additional time and travel involved in verification, notification and response to an emergency in off hours.

The instructions to the **Operating Personnel** are applicable to hours of both daylight and darkness. Procedures for contacting proper personnel and officials are applicable to hours of both daylight and darkness. Until reports can be verified or proven to be false, a warning shall be given in the interest of public safety. There is a telephone at the dam (266-3869). There are two sources of AC power and an inverter DC backup system. The spillway bays are air inflated rubber dams which are computer controlled to maintain a constant reservoir level. They can be deflated manually without electrical power. There are overhead lights installed at the dam. The procedures for contacting the proper personnel would be the same as those given in sections **"Failure is Imminent or Has Occurred"** or **"Potentially Hazardous Situation Is Developing"**.

D. Response During Periods of Adverse Weather

No additional actions can be taken to respond to an emergency situation or failure at the dam during inclement weather, other than those taken during clear weather. The response time will be longer because of the additional time and travel involved in notification and response to an emergency during adverse weather. Travel time from Toston to Broadwater Dam is about 15 minutes during good weather. During periods of heavy snowfall, the access

road to the powerhouse is plowed by the Broadwater County Road Crew.

Access roads to Broadwater Dam and the surrounding area are shown in Appendix F, Figures 1 through 4, pages F-3 through F-6. Should the main roads become impassable, secondary access to the dam is by a road at the canal crossing, which goes over rough terrain and requires a four-wheel drive vehicle. The **Plant Operator** is provided a four-wheel drive vehicle, and there are four-wheel drive vehicles available in Helena for personnel leaving from Helena. Figure 4 in Appendix F is a project map that shows the Broadwater-Missouri Project in relation to other water projects downstream.

Instrumentation and surveillance systems are installed on the dam. Even when the dam is unmanned, dam failure would be detected during adverse weather by a low reservoir alarm. If an adverse condition is found, then the notification would follow the procedures in the sections called "**Failure is Imminent or Has Occurred**" or "**Potentially Hazardous Situation Is Developing**".

E. Availability and Use of Alternative Systems of Communication

Communication for the initial warning will be by telephone or driving directly to the **Sheriff's Office**. Once the initial warning is given, the **Broadwater County Sheriff's Office** can use its radio communication system. DES also has a radio communication system. The Sheriff's and DES's systems do not operate on the same frequency, but the two systems could be used concurrently through the sheriff's dispatch operator.

F. Emergency Supplies and Resources

1. Stockpiling of material and equipment for emergency use or repairs.

There are no emergency supplies stockpiled at the site. Sources of equipment for use during an emergency are listed below. We can visualize no case in which stockpiling materials or use of equipment could reduce the effect of a dam failure. The processes involved in the destruction of a dam are too powerful to be mitigated by the emergency use of machinery or materials. However, the department will determine if equipment would be useful and will contact the contractors if necessary. The following area contractors have machinery which could be made available in an emergency:

<u>Name</u>	<u>Phone Number</u>
A & W Excavating	227-6806
Broadwater County Shop	266-3429
Highway Department Maintenance Shop (Townsend). . .	266-5571
Norman Excavating	227-6826
Benson Excavation, Inc.	443-4760
Greenway, Inc..	442-5500
Hall Earth Moving	443-2245
Helena Sand & Gravel Co.	442-1185
Highway Department Maintenance Shop (Helena). . .	444-6155
Ingram-Clevenger	442-5102
Jim Stout Excavation	443-7593
Magille & Son	442-5283
Maronick Construction Co.	227-5821

2. Coordination of Flows

Broadwater-Missouri Dam is a diversion dam on the Missouri River. Therefore, runoff forecasts are needed to operate the dam and anticipate any problems that may arise as a

result of the high runoff. The Project Section Supervisor, Mel McBeath, phone (444-6646) is responsible for communicating with the National Weather Service (453-2081) to obtain runoff forecasts.

As discussed in paragraph C, the spillway bay rubber dams are computer controlled to maintain a constant reservoir level. If the level increases, an alarm will be automatically sent to the **Plant Operator** at a remote location. The **Plant Operator** can lower the rubber dams manually.

There are some reservoirs upstream of the dam that regulate stream flows.

The dam is an overflow diversion dam; therefore, there is very limited control over the river flows downstream of the dam.

3. Alternative sources of power for spillway gate operation and other emergency uses.

The dam is automatically operated. A 100-kv line, a 12-kv line and a battery bank provide electrical power to the operation system. The system will switch automatically between alternate power supplies.

G. Other Concerns and Actions

None

V. APPENDICES

	<u>Page</u>
APPENDIX A: Description of Broadwater-Missouri Dam	A-1
APPENDIX B: Broadwater-Missouri Power Project Dam-Break Analysis .	B-1
APPENDIX C: Flood Inundation Maps	C-1
APPENDIX D: Plans for Posting the EAP, Training, Testing, and Annual Review.	D-1
1. Posting the EAP	D-2
2. Annual training of the project operators and other responsible personnel.	D-3
3. Annual Review	D-3
4. Test of the State of Readiness.	D-4
APPENDIX E: Documentation	E-1
APPENDIX F: Location Maps	F-1
APPENDIX G: Telephone Directory	G-1

APPENDIX A

DESCRIPTION OF BROADWATER-MISSOURI DAM

APPENDIX A

DESCRIPTION OF BROADWATER-MISSOURI DAM

Broadwater-Missouri Dam is located in Broadwater County about five miles south of Toston, Montana, on the Missouri River (see Appendix F, figures 1 through 4). The dam is owned and operated by the Montana Department of Natural Resources and Conservation (DNRC).

The concrete gravity dam was finished in 1940. It is 40 feet high to the top of the gravity overflow section, and 56 feet high to the top of the retaining wall. The dam is 705 feet wide, with a spillway capacity of 39,500 cubic feet per second (cfs) at the normal operating pool elevation of 3952.6. A powerhouse was constructed on the left (looking downstream) bank of the river through the dam. A 10 megawatt turbine-generator unit was installed in the powerhouse. Power was first generated in July 1989.

Water from the reservoir is used for irrigation. Water is delivered to purchasers through a canal system that is owned by DNRC. The Main Canal is 1.5 miles long and has a capacity of 342 cfs; the West Canal is 12.4 miles long and has a capacity of 90 cfs; and the East Canal is 34.3 miles long and has a capacity of 252 cfs. An 84-inch diameter steel pipe flume, 667 feet long, crosses the Missouri River to the East Canal.

The areas upstream and downstream of the dam are similar. The river is in a narrow, deep valley both upstream and downstream. The hills are fairly steep

and rock-covered; an occasional rock outcropping can be seen. The valley broadens out about five miles downstream. The Montana Rail Link railroad follows the river on the right bank (looking downstream). A gold mine and the U.S. Bureau of Reclamation Crow Creek Irrigation pumping plant are on the left bank (looking downstream) upstream of the dam. The irrigation canal follows the river on the left bank from the dam until it gets to a division structure. A steel pipe flume carries water across the river to a canal on the right bank, and some water remains in a canal that follows the left bank.

APPENDIX B

BROADWATER-MISSOURI POWER PROJECT

DAM-BREAK ANALYSIS

APPENDIX B

BROADWATER-MISSOURI POWER PROJECT

DAM-BREAK ANALYSIS

A dam-break analysis was conducted to assess the downstream effect of the flood waves resulting from a hypothetical failure of the Broadwater-Missouri (Toston) Dam. Three dam collapse scenarios were considered: (1) during the probable maximum flood (PMF) (495,000 cfs), (2) during the project maximum flood (79,000 cfs), and (3) during the maximum power generation flow of the project (6,000 cfs). Since the tailwater at Broadwater-Missouri Dam during the PMF would reach about the same level as the headwater, the effect due to dam-break waves would be minimal. Therefore, no further analysis was performed. For the remaining two scenarios studied, effect of dam-break waves, in terms of maximum elevation, maximum flow, travel time, and maximum velocity, were assessed for fourteen (14) downstream sections. Eight of these cross sections are shown in Table B-2 on page B-4.

It is important to examine the suitability and applicability of each mathematical model for dam-break wave calculations. Many mathematical models are available to calculate the dam-break waves. A summary of the various models can be found from the proceedings of the Dam-Break Flood Routing Model Workshop organized by the U.S. Water Resources Council, which were published by the National Technical Information Service of the U.S. Department of Commerce. For the case of Broadwater-Missouri Dam, the model developed by the U.S. National Weather Service (DAMBRK) was used (Ref. 4).

The breach assumptions and results are summarized in Tables B-1 and B-2 and in Figure B-1.

Table B-1

Breach Assumptions

Scenario I - Project Maximum Flood at 79,000 cfs

Breach Width = 375 ft.

Spillway Gates Fully Open

Time to Failure: 0.2 hours

Scenario II- Power Generation Operation at 6,000 cfs

Breach Width = 375 ft.

Spillway Gates Fully Closed

Time to Failure: 0.2 hours

Conclusion

The results shown in Table B-2 indicate that the dam-break flood wave created by dam failure during the project maximum flood (79,000 cfs) will attenuate from about 11.0 feet to about 1.1 feet within the first five miles below the dam. During the maximum power generation flow (6,000 cfs), the dam-break flood wave will attenuate from 30.2 feet to about 7.6 feet within the first five miles

TABLE B-2
DAM-BREAK ANALYSIS RESULTS

Scenario I - Project Maximum Flood at 79,000 cfs

Cross Section	Distance From Dam (Miles)	Peak Discharge (cfs)	Wave Velocity (fps)	Travel Time		Wave Height (ft.)	Water Surface Elevation	
				Initial hrs.	Peak hrs.		Before Failure (ft.)	After Failure (ft.)
Dam	0	145,367	10.97	0.20	0.55	11.01	3946.90	3957.91
A	2.1	118,799	11.82	0.54	0.55	3.12	3934.18	3937.30
B	5.4	107,010	8.05	0.92	1.57	1.11	3912.01	3913.12
C	11.3	101,478	5.88	0.98	3.31	0.85	3875.30	3876.15
D	19.9	100,324	8.05	2.00	4.77	1.28	3847.72	3849.00
E	17.4	99,729	6.84	2.53	5.29	1.03	3837.29	3838.32
F	19.9	99,519	5.88	2.91	5.93	0.91	3816.68	3817.59
G	22.3	98,907	2.66	3.60	7.12	0.71	3805.92	3806.63
H	23.5	98,573	2.23	3.97	9.64	0.44	3803.68	3804.12

Scenario II - Power Generation Operation at 6,000 cfs

Cross Section	Distance From Dam (Miles)	Peak Discharge (cfs)	Wave Velocity (fps)	Travel Time		Wave Height (ft.)	Water Surface Elevation	
				Initial hrs.	Peak hrs.		Before Failure (ft.)	After Failure (ft.)
Dam	0	167,530	12.37	0.00	0.01	30.25	3922.35	3952.60
A	2.1	71,890	10.93	0.18	0.47	15.08	3916.15	3931.23
B	5.4	43,571	5.85	0.54	1.23	7.60	3899.21	3906.81
G	11.3	26,310	4.62	1.83	4.04	3.34	3868.39	3871.73
D	14.9	24,566	2.85	3.26	5.65	2.78	3839.17	3841.95
E	17.4	22,585	4.49	0.10	4.04	3.10	3828.59	3831.69
F	19.9	21,891	3.67	4.88	7.77	2.77	3808.99	3811.76
D	22.3	20,435	1.62	6.36	9.30	1.48	3800.44	3801.92
H	23.5	19,029	1.23	7.00	10.29	1.07	3798.46	3799.53

Cross Section	Description
A	First house downstream of dam
B	Town of Toston
C	Houses between river and railroad
D	Cemetery
E	Grain bins
F	Townsend
G	Canyon Ferry Reservoir delta
H	Canyon Ferry Reservoir

Revised 6/1/91


below the dam. At that point the flood wave from both flood conditions varies from 7.6 feet to 0.4 feet until it reaches Canyon Ferry Reservoir. The dam-break flood wave created by dam failure during the project maximum flood and during the maximum power generation flow will have peak discharges at the dam of 145,367 cfs and 167,530 cfs, which will cause flooding as indicated on Figures C-1 through C-6, pages C-3 through C-13, Broadwater-Missouri Dam Flood Inundation Maps.

The failure of Broadwater-Missouri Dam will raise the water surface at the head end of Canyon Ferry Reservoir by about 1.1 feet. This will dissipate to near zero by the time that the wave reaches the dam, 25 miles downstream.


References

1. Stoker, J. J. 1957. "Water Waves." Inter-Science Pub., New York.
2. Su, S. T. 1977. "Unsteady Flow Analysis of Dam-Break Waves." Proceedings of Dam-Break Flood Routing Model Workshop, Water Resources Council, NTIS P8-275 437.
3. Su, S. T. and A. H. Barnes. 1970. "Geometric and Frictional Effects of Sudden Releases." Journal of Hydraulic Division, American Society of Civil Engineers, HY11. Nov.
4. Fread, D.L., 1984, DAMBRK: the National Weather Service Dam-Break Flood Forecasting Model. National Weather Service.
5. Tudor Engineering Company. 1982. Broadwater Power Project. License Application to Federal Energy Regulatory Commission.
6. Rouse, H. 1950. Engineering Hydraulics. John Wiley and Sons, Inc. New York.


FIGURE B-1 BREACH PARAMETERS



ELEVATION OF THE DAM SHOWING BREACH PARAMETERS NO SCALE




PROJECT MAXIMUM FLOOD AT 79,000 cfs
WATER SURFACE ELEVATIONS



POWER GENERATION OPERATION AT 6,000 cfs
WATER SURFACE ELEVATIONS

APPENDIX C
FLOOD INUNDATION MAPS



A	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time Initial (HRS)	Travel Time Peak (HRK)	Wave Height (Ft)
PMFB	2.1	118,799	11.82	0.54	0.98	3.1
PGOB	2.1	71,890	10.93	0.18	0.47	15.1

BROADWATER-MISSOURI DAM INUNDATION MAPS




FIGURE C-2


LEGEND

Cross Section	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time Initial (HRS)	Travel Time Peak (HRS)	Wave Height (FT)
PMFB						
PGOB						

Flood Routing Cross Section


- Project Maximum Flood Breach
- - - Power Generation Operation Breach


SCALE 1"=24000



Users should understand that the inundation maps are only intended to be a guide and that the area subject to inundation during an actual failure may be different depending upon mode failure and reservoir inflow conditions.

B	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time Initial (HRS)	Travel Time Peak (HRS)	Wave Height (FT)
PMFB	5.4	107,010	8.05	0.92	1.57	1.1
PGOB	5.4	43,571	5.85	0.54	1.23	7.6





T. 6 N. - R. 1 E.
T. 6 N. - R. 2 E.

Match to Figure C-5

D	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time		Wave Height (Ft)
				Initial (HRS)	Peak (HRK)	
PMFB	14.9	100,324	4.08	2.00	4.77	1.3
PGOB	14.9	24,566	2.85	3.26	5.65	2.8

ROAD

RIVER

LANE

CARSON

LITENING

BARN

LANE

LANE

FLYNN

HIGHWAY 287

Match to Figure C-3

FIGURE C-4
LEGEND

Cross Section	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time		Wave Height (Ft)
				Initial (HRS)	Peak (HRK)	
PMFB						
PGOB						


Flood Routing Cross Section

- Project Maximum Flood Breach
- - - Power Generation Operation Breach

SCALE 1:24000

1000 0 1000 2000 3000 4000 5000 6000 7000 FEET

Users should understand that the inundation maps are only intended to be a guide and that the area subject to inundation during an actual failure may be different depending upon mode failure and reservoir inflow conditions



H	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time		Wave Height (Ft)
				Initial (HRS)	Peak (HRS)	
PMFB	23.5	98,573	2.23	3.97	9.64	0.4
PGOB	23.5	19,029	1.23	7.00	10.29	1.1

G	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time		Wave Height (Ft)
				Initial (HRS)	Peak (HRS)	
PMFB	22.3	98,907	2.66	3.60	7.12	0.7
PGOB	22.3	20,435	1.62	6.36	9.30	1.5

F	Distance from Dam (MILES)	Peak Discharge (CFS)	Wave Velocity (FPS)	Travel Time		Wave Height (Ft)
				Initial (HRS)	Peak (HRS)	
PMFB	19.9	99,519	5.56	2.91	5.93	0.9
PGOB	19.9	21,891	3.67	4.88	7.77	2.8

APPENDIX D

PLANS FOR POSTING THE EAP, TRAINING, TESTING, AND ANNUAL REVIEW

APPENDIX D

Plans for Posting the EAP, Training, Testing, and Annual Review

1. Posting the EAP

A copy of the notification flowcharts for both a "failure is imminent or has occurred" and a "potentially hazardous situation is developing" scenarios shall be posted at the following locations:

1. Broadwater Power Project Control Room
2. State Water Projects Bureau Office - Helena
3. Plant Operator's Home
4. Broadwater County DES Coordinator - Townsend
5. Broadwater County Sheriff's Office - Townsend
6. Federal Energy Regulatory Commission - Portland Office
7. Broadwater-Missouri Water Users Association Directors
8. Department of Natural Resources and Conservation
Library
9. State Library
10. State Disaster and Emergency Services - Helena
11. Ditch Rider
12. Montana Power Company - Butte

2. Annual training of project operators and other responsible personnel

Training will be provided on a yearly basis for all Project Personnel involved with the EAP at the dam. The Broadwater county sheriff and the DES coordinator, and the state DES personnel will be invited to participate in the training session. This training will include, but is not limited to:

- a. A general discussion on how to respond properly to an emergency situation.
- b. Procedures to follow throughout an emergency.
- c. Basic communications skills - how and when to use them. Samples of typical communications during implementation of the EAP warning flowchart will be given to all personnel during this training.
- d. The flowcharts will be reviewed for each failure scenario.

This training will be held once every 12 months at a time and date to be determined by the EAP coordinator and will be held in conjunction with the annual review of the EAP.

3. Annual Review.

A comprehensive review of the adequacy of the EAP will be conducted each year. This review is to verify phone numbers, names, position titles, etc. A determination of any new developments or other changes downstream or elsewhere will be made

to determine whether any revisions to the current EAP are necessary. Revisions will be made to the current EAP as necessary. Revisions will be made immediately after any changes are discovered and updated pages will be mailed to all holders of the EAP. A statement will be furnished to the Regional Director prior to December 31, which states that the EAP has been thoroughly reviewed and includes the date it was last tested. Attached to this statement will be any updated pages, or a separate statement that no revisions or updates were needed.

4. Test of the state of readiness.

A. Review of annual test procedure.

Review of the annual test procedure will be summarized and documented by the Department with input from the Broadwater County DES coordinator, State DES, and the Broadwater County Sheriff.

B. Annual test procedure.

The SWPB will coordinate the test with the Broadwater County DES coordinator. The DES coordinator or the Department will give a message to the project operator. The message will describe the emergency situation. The project operator will drive to the dam, check for the condition, and then proceed with the test. The **Plant Operator** will decide which Notification Flowchart is appropriate for the message received, and follow the notification procedure for that particular condition. The test will stop once

the call has been received by all the agencies and personnel listed on the appropriate flowchart.

All of the alarm systems will be tested at this time, to make sure that they are operational. Repairs will be made to the system if necessary.

C. Action to be taken.

If the test indicates that the EAP needs revision, the EAP will be revised by the SWPB when the yearly revision is completed.

D. Who determines if test is successful.

The SWPB will review and evaluate the test results following consultation with plant and DES personnel. The SWPB will determine if the test is successful based upon recommendations received from the local and state DES personnel.

E. Submitting test results.

The SWPB will submit the test results to the Regional Director of FERC within 30 days of the test.

F. Checkpoints.

The following checkpoints will be used to help determine if the test is successful according to FERC requirements.

1. Time project operator becomes aware of the problem at the dam.
2. Time it takes project operator to make first call, and any subsequent calls to the other personnel listed on the Notification Flowcharts.
3. How the message was received by all parties.

APPENDIX E
DOCUMENTATION

Broadwater-Missouri EAP

[illegible]

APPENDIX F
LOCATION MAPS




Figure 1. Broadwater-Missouri Dam Location




Figure 3. Broadwater County Access Routes




Figure 4. Broadwater-Missouri Project

APPENDIX G

TELEPHONE DIRECTORY

APPENDIX G

TELEPHONE DIRECTORY

The telephone numbers are listed in order of priority.

1. SHERIFF

Broadwater County. 266-3441

2. DISASTER AND EMERGENCY SERVICES

Broadwater County. Business 266-3441

Mike Wenzel EOC 266-5214

Home 266-3220

Church 266-4219

Montana Disaster and Emergency Services

Division (Helena) 444-6911

3. MONTANA DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION (DNRC)

Power Plant at the dam 266-3869

Auxiliary number (FAX) 266-3817

Chatter Box 266-4454

State Water Projects Bureau. Office 444-6646

Bureau Chief: Glen McDonald. Home 443-5758

Supervisor, Walt Anderson Home 443-3016

Plant Superintendent, Mike Sims Home 442-0552

Pager 449-1550

Plant Operator, Brian Carroll Home 266-4212

Pager 449-1549

Plant Operator, Jim Beck. Home 266-3026

Supervisor, Project Rehabilitation Section:

Greg Ames Home 449-6261
Dam Safety Engineer: Arthur Taylor . Home 443-0315
Civil Engineer: Robert Clark Home 227-7046
Civil Engineer: John Sanders Home 443-0243

Supervisor, Project Section:

Mel McBeath Home 933-5556
Water Resources Division Office 444-6601
Administrator: Gary Fritz Home 443-3631
Division Engineer: Rick Bondy . . . Home 442-5763
Assistant Administrator: Robin Harper . Home 227-5982
Water Operations Bureau Office 444-6610
Bureau Chief: Laurence Siroky Home 442-2806
Dam Safety Supervisor: Mike Oelrich Home 449-5668
Civil Engineer: Gary Fischer . . . Home 442-8818
Department Director Office 444-6699
Mark Simonich Home
Deputy Director: Wayne Wetzel Home 227-6419
Information Officer: Office 444-6743
James Bond Home 458-5014

4. DITCH RIDER

Gordon Brug Home 266-5798

5. NATIONAL WEATHER SERVICE

Helena 449-5204
Great Falls 453-2081

6. Canyon Ferry

Power Plant Operator (24 hrs.) 475-3310

7. BROADWATER-MISSOURI WATER USERS ASSOCIATION

President: Bob Davis 266-3786

Vice President: Bob Hensley 266-3633

Directors:

Jed Stanfill. 266-3709

Don Shearer 266-3785

Pat Antonick. 266-3059

Dave Rowland. 266-4447

Keith Kirscher. 266-3785

8. GOVERNOR'S OFFICE 444-3111

Citizen's Advocate 1-800-332-2272

9. FEDERAL ENERGY REGULATORY COMMISSION

Portland Regional Office

Arthur C. Martin Office 503-326-5840

Home 503-635-1472

Harry T. Hall Office 503-326-5844

Home 503-636-6861

10. SOURCES OF AIRCRAFT

Name	Phone Numbers
------	---------------

GOVERNMENT AGENCIES

Department of	Office	444-2074
State Lands	Hangar	444-4766
Rick Burger	Home	442-9531
Summer Fire Dispatch		444-4242
Tim Pfahler	Home	458-5136

PRIVATE FLYING SERVICES

Helena

Bison Aviation	Office	443-0066
Corporate Air	Office	443-4543
Corporation		
Morrison's Flying Service	Office	442-2190
	Jeff Morrison. . . Home	442-8547
3-D Aviation	Office	449-2369
Wolf Aviation	Office	443-1225

Billings

Billings Deaconess Hospital	Office	657-4000
		1-800-325-1774
Billings Flying Service	Office	248-1741
Corporate Air	Office	248-1541
Lynch Flying Service, Inc.	Office	252-0508

Saint Vincent Hospital and
Health Center

Office. . . . 1-800-538-4357

Bozeman

Central Helicopters, Inc.

Office 586-9185

